



CENTRE FOR TESTING AND CERTIFICATION - MECH-TEST
Mechanical Laboratory

05-077 Warszawa-Wesoła, ul. Klonowa 22
tel.: +48 603 23-26-45, e-mail: cbc.mech.test@gmail.com, www.cbc.org.pl

Date 4.06.2018

TEST REPORT NO. CBC-050/2018

Page 1 of 4

Subject of testing:	<i>Walking tables</i>	Classification according to PN-EN ISO 9999:2011 :	12 06 12
Type / Model:	<i>NAVIGATOR (with rotating arm pads)</i>	Art no.:	<i>NRRCHL60</i>
		SN:	<i>(01) 05901912630024 (11) 180320 (21)0444</i>
Manufacturer:	<i>REHASENSE Sp. z o.o. Sulejowska 45 97-300 Piotrków Tryb.</i>	Number of specimens:	<i>1</i>
Applicant:	<i>A-Net s.c. 93-469 Łódź, ul. Łaskowice174</i>		
Kind of testing	<i>Testing scope according to application of Client Mechanical testing for conformity with PN-EN ISO 11199-3:2008</i>		
Test started:	<i>30.05.2018</i>		
Test finished:	<i>4.06.2018</i>		

Approved by:

DYREKTOR

mgr inż. Andrzej Tkaczyk

Special comments / enclosures:

Copyright © 2012 by Centre for Testing and Certification (applicable to report form)

Test results refer only to tested units.

Test results reported here are not applicable to the further modifications of the product affecting his structure, material or technology

This test report shall be neither copied differently as in the whole nor be published without written consent of the Laboratory



CHARACTERISTIC OF PRODUCT

Name : NAVIGATOR (with rotating pads)	Dimension of rollator: --
Art no.: NRRCHL60	SN: (01) 05901912630024 (11) 180320 (21)0444
Maximum permissible user mass: 150 kg	Mass of rollator: 10,32 kg

Description		Comments	
Elements/parameters/materials/dimensions			
Dimensions of walking rollator (fig. 2 PN-EN ISO 11199-2)	Distance between handgrips (dimension 2)	460 mm	
	Angle between of handgrip axis and direction of movement (α)	0°	
	Height of rollator (dimension 6)	997 mm	min.
		1242mm	max.
	Support height (dimension 5)	903 mm	min.
		1148 mm	max.
	Width of rollator (max.) (dimension 4)	603/635 mm	
	Turning width (dimension 1)	845 mm	
Length of rollator (max.) (dimension 3)	660/680 mm		
Dimensions of folded rollator (mm)		997 x 680 x 315	
Fig. 3	Handgrip - diameter	32 mm	
	Handgrip - length	100 mm	
Wheels of rollator	Front wheels - quantity	2	castor wheels
	Front wheels - diameter	202 mm	
	Front wheels - width	32/35 mm	
	Front wheels - brake	Not any	
	Rear wheels - quantity	2	castor wheels
	Rear wheels - diameter	202 mm	
	Rear wheels - width	32/35 mm	
	Rear wheels - brake	Included	
Tip	Diameter		
	Material	Not any	
	Colour		
Material of rollator (fig. 1)	Front legs	Aluminum,	
	Bracing member (no. 8)	Steel,	
	Rear legs	Hard plastic,	
	Height adjusting device (no. 4)	Bolts, nuts	
	Handgrip (no 5), Brake elements	Hard plastic	



SN (01) 05901912630024 (11) 180320 (21) 0444	Navigator
	2018-03-20
	NRRSGL600
	150 kg
	5 Kg
	62.0 cm
	CE L
	REHA SENSE Sp. z o.o. Sulejowska 45 97-300 Piotrków Tryb. Poland
	5 901912 630024

RESULT OF TESTS ACCORDING TO PN-EN ISO 11199-3:2008

Requirements according to clause	Test method according to clause	Checked characteristics/assemblies/parameters	Real value	Test result	Comments	
4.1	Stability					
	5.4	product used only in premises	Forward-direction stability	10,9° Conf.	Pos.	≥ 10,0°
	5.5		Backward-direction stability	12,5° Conf.	Pos.	≥ 4,0°
	5.6		Sideway-direction stability	3,5° Conf.	Pos.	≥ 3,5°
	5.4	product also used outside	Forward-direction stability	--	N/A	≥ 15,0°
	5.5		Backward-direction stability	--	N/A	≥ 7,0°
5.6	Sideway-direction stability		--	N/A	≥ 4,5°	
4.2	Brakes					
	V/I	Ease service of running brakes while driving in the products used outside and equipped with more than 2 wheels	Conf.	Pos.		
	V/I	The presence of the parking brakes in all tables for walking and the simplicity of their handling	Conf.	Pos.		
4.2	V/I	Adjustable brakes if their performance deteriorates	Conf.	Pos.		
	Meas., 5.8.2.2	Brake grip distance (fig. 8)	71mm Conf.	Pos.	≤ 75 mm	
	5.8.2.3	Running brake effectiveness	Conf.	Pos.	Movement of rollator ≤ 10 mm in 1 minute	
	Meas., 5.8.3.2	Force to set parking brake	25 N Conf.	Pos.	≤ 60 N manual	
	Meas., 5.8.3.2	Force to release parking brake	10 N Conf.	Pos.	≤ 40 N manual	
	5.8.3.3	Parking brake effectiveness, test to forward	Conf.	Pos.		
	5.8.3.4	Parking brake effectiveness, test to reverse	Conf.	Pos.		
	V/I	Brake not adversely affected by folding, unfolding or adjusting actions of mechanisms	Conf.	Pos.		
4.3	Mechanical durability					
	5.9.2	Static loading resistance of resting seat	Conf.	Pos.	loading = 1,2 x mass of user (180kg.) 1min.	
	5.10	Static loading resistance of product	Conf.	Pos.	loading = 1,5 x mass of user, 5 s NOTE 4	
4.4	5.11	Fatigue loading resistance of product	Conf.	Pos.	loading = 0.8 x mass of user, 200 000 cycles, f ≤ 1 Hz	
	Manoeuvrability					
	Measur.	Diameter of wheels (front/rear)	202/202 mm Conf.	Pos.	≥ 75 mm	
4.5	Measur.	Diameter of wheels of the product used outside (front/rear)	--	N/A	≥ 180 mm	
	Measur.	Width of wheels (front/rear)	32 mm Conf.	Pos.	≥ 22 mm, 5 mm above ground	
	Handgrip					
4.5	Measur.	Handgrip - diameter	32mm Conf.	Pos.	≥ 20 mm l ≤ 50 mm	
	V/I	Confidence to handle mounting for handgrip	Conf.	Pos.		
	V/I	Ease to change or ease of cleaning	Conf.	Pos.		
4.6	Leg section and tip					
	V/I	Puncture resistant tip	--	N/A		
	V/I	Convertibility of the tip	--	N/A		
	V/I	No staining of the ground	--	N/A		
	Measur.	Diameter of the tip	--	N/A	≥ 35 mm	
4.7	Adjusting devices					
	V/I	Confidence of mounting of adjustable handles	Conf.	Pos.		
	V/I	Marking the maximum allowable extension of adjusting devices	Conf.	Pos.		
	V/I	Reliability of the activity of adjusting mechanisms after the fatigue test	Conf.	Pos.		
4.8	Resting seat					
	5.9	Resting seat -- static loading durability	Conf.	Pos.	loading 225 kg, 1 min.	
4.9	Materials and finish					
	ISO 10993-1	Biocompatibility of material with human body	--	N/T		
	V/I	Free of discolouring of skin or clothing in contact with product materials	Conf.	Pos.		
	V/I	No burrs, sharp edges and protrusions	Conf.	Pos.		

Requirements according to clause	Test method according to clause	Checked characteristics/assemblies/parameters	Real value	Test result	Comments	
4.10	6.2, V/I	Marking and labelling of product				
		Information to be included on the product and / or accessories:				
		- Maximum permissible user weight	Included	Pos.		
		- Maximum load of accessories	Included	Pos.		
		- Manufacturer's name or trade name and address	Included	Pos.		
		- The name and / or id. number of the product	Included	Pos.		
		- Month and year of production	Included	Pos.		
		- Marking of maximum extension of the height adjustment	Included	Pos.		
		- Max. limit of range adjustment	Included	Pos.		
		- Maximum width of the walking bicycle	Included	Pos.		
- Product intended for outdoor/indoor use	Included	Pos.				
4.10	6.3, V/I	The content of the documentation:				
		- Maximum supporting height	Included	Pos.		
		- Minimum supporting height	Included	Pos.		
		- Maximum width of the turning	Included	Pos.		
		- Maintenance instructions including brake adjustment as a result of wear and the required terms of control	Included	Pos.		
		- manual cleaning	Included	Pos.		
		- Instructions for assembly, adjustment of all kinds, folding and unfolding	Included	Pos.		
- Warnings and advice about precautions relating to safe distances between moving and stationary parts (see EN 12182, Clauses 12 and 13)	Included	Pos.				

Pos. – positive; Neg – negative; N/T – not tested; N/A – not applicable; N/R – not required, N/O – not occurred, V/I – visual inspection, Conf. – conformed

TEST CONDITIONS

Ambient temperature	21°C	Required temperature 21°C ±5°C
Relative humidity of air Humidity	60%	N/R
Comments:		
All tests were performed at maximum height of walking stick.		
All tests performed in the least stable position of self-adjusting wheels.		
Sequence of tests: stability test, static loading test, fatigue test.		
One verticalizer was tested.		
During visual inspection before testing any visible defects that could have influence on test results were not stated		

Pos. – positive; Neg – negative; N/T – not tested; N/A – not applicable; N/R – not required, N/O – not occurred, V/I – visual inspection, Conf. – conformed

NOTE 1. Conformity assessment of product according to standard requirements refer to the scope of mechanical ordered by client

NOTE 2: During visual inspection before testing any visible defects that can have an effect on test results were not stated.

NOTE 3: Sample/object for testing was delivered to the Laboratory by the Orderer.

NOTE 4: Product resistance tests for static load (p. 5.10) were performed by loading the product in accordance with Fig. 7 (EN ISO 11199-3). The load of 1,5 x 150kg = 225 kg was applied at point 8 of reference line 9. The test result positive.

CONCLUSIONS:

Test object **conforms** with requirements of PN-EN ISO 11199-3:2008 within mechanical testing ordered by client excluding testing of material biocompatibility with human body according to PN-EN ISO 10993-1:2010.

---- END ----